

COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
LAND DEVELOPMENT DIVISION – SUBDIVISION
TRACT NO. 070647 (Rev.)

Page 1/1

TENTATIVE MAP DATED 01-22-2014
EXHIBIT MAP DATED 01-22-2014

It is recommended that this tentative map not be approved at this time. This recommendation is based upon information or lack of information that is available concerning the subject property. The removal of this recommendation is contingent upon the submission and satisfactory review of the following:

- As previously requested, an approved hydrology report, and Low Impact Development Plan (LID). Please see attached Storm Drain and Hydrology review sheet. The hydrology report, LID shall be submitted directly to Public Works.

HW

JK

Prepared by John Chin

Phone (626) 458-4918

Date 02-13-2014

tr70647L-rev2.doc

http://planning.lacounty.gov/case/view/tr_070647/



COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS
CITY ENGINEER/SUPERINTENDENT OF STREET
LAND DEVELOPMENT DIVISION
HYDROLOGY UNIT

TRACT MAP NO. 70647

TENTATIVE MAP DATED 01/22/14
EXHIBIT MAP 01/22/14

Approval and clearance of the tentative map is subjected to compliance with the following **drainage** comments:

1. Prior to tentative map approval for drainage, submit a hydrology report showing the extent of drainage impacts and provide mitigation acceptable to the County. The analysis should address increases in runoff, any change in drainage patterns, debris producing areas, and the capacity of existing storm drain facilities. Provide line identification of all proposed drainage facilities. Preliminary soils and geology reports related to debris, retention, and detention basins may be required based on geographic and adverse geotechnical conditions. Provide engineering calculations to support sizing of debris, retention, and detention basins. Provide approximate flood hazard and bank erosion setbacks and lot identifications (as needed). Show slopes for existing and proposed streets and/or driveways. Provide a drainage/grading covenant for any offsite work.
 - The latest Hydrology Report was reviewed on 10/10/13 and was not approved.
2. A water quality section of the Hydrology Report is required to comply with the LID requirements of Los Angeles County Code Section 12.84 (<http://library.municode.com/index.aspx?clientId=16274>).

By

Ernesto J Rivera

Date 02/13/14 Phone (626) 458-4921

COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
LAND DEVELOPMENT DIVISION – SUBDIVISION
TRACT NO. 070647 (Rev.)

Page 1/1

TENTATIVE MAP DATED 01-22-2014
EXHIBIT MAPDATED 01-22-2014

- If this recommendation of disapproval is changed to a recommendation of approval based on additional information, the following reports would be recommended for inclusion in the conditions of tentative approval:


Prepared by John Chin
tr70647L-rev2.doc
http://planning.lacounty.gov/case/view/tr_070647/

Phone (626) 458-4918

Date 02-13-2014

The following reports consisting of ___ pages are the recommendations of Public Works.

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. Details and notes shown on the tentative map are not necessarily approved. Any details or notes which may be inconsistent with requirements of ordinances, general conditions of approval, or Department policies must be specifically approved in other conditions, or ordinance requirements are modified to those shown on the tentative map upon approval by the Advisory agency.
2. Easements are tentatively required, subject to review by the Director of Public Works to determine the final locations and requirements.
3. Easements shall not be granted or recorded within areas proposed to be granted, dedicated, or offered for dedication for public streets, highways, access rights, building restriction rights, or other easements until after the final map is filed with the Registrar-Recorder/County Clerk's Office. If easements are granted after the date of tentative approval, a subordination must be executed by the easement holder prior to the filing of the final map.
4. In lieu of establishing the final specific locations of structures on each lot/parcel at this time, the owner, at the time of issuance of a grading or building permit, agrees to develop the property in conformance with the County Code and other appropriate ordinances such as the Building Code, Plumbing Code, Grading Ordinance, Highway Permit Ordinance, Mechanical Code, Zoning Ordinance, Undergrounding of Utilities Ordinance, Water Ordinance, Sanitary Sewer and Industrial Waste Ordinance, Electrical Code, and Fire Code. Improvements and other requirements may be imposed pursuant to such codes and ordinances.
5. Adjust, relocate, and/or eliminate lot lines, lots, streets, easements, grading, geotechnical protective devices, and/or physical improvements to comply with ordinances, policies, and standards in effect at the date the County determined the application to be complete all to the satisfaction of Public Works.
6. If applicable, quitclaim or relocate easements running through proposed structures.

7. All easements existing at the time of final map approval must be accounted for on the approved tentative map. This includes the location, owner, purpose, and recording reference for all existing easements. If an easement is blanket or indeterminate in nature, a statement to that effect must be shown on the tentative map in lieu of its location. If all easements have not been accounted for, submit a corrected tentative map to the Department of Regional Planning for approval.
8. Prior to final approval of the tract map submit a notarized affidavit to the Director of Public Works, signed by all owners of record at the time of filing of the map with the Registrar-Recorder/County Clerk's Office, stating that any proposed condominium building has not been constructed or that all buildings have not been occupied or rented and that said building will not be occupied or rented until after the filing of the map with the Registrar-Recorder/County Clerk's Office.
9. Place standard condominium notes on the final map to the satisfaction of Public Works.
10. Label driveways and multiple access strips as "Private Driveway and Fire Lane" and delineate on the final map to the satisfaction of Public Works.
11. Reserve reciprocal easements for drainage, ingress/egress, sewer, water, utilities, and maintenance purposes, etc., in documents over the private driveways to the satisfaction of Public Works.
12. Remove existing buildings prior to final map approval. Demolition permits are required from the Building and Safety office.
13. A final tract map must be processed through the Director of Public Works prior to being filed with the Registrar-Recorder/County Clerk's Office.
14. Prior to submitting the tract map to the Director of Public Works for examination pursuant to Section 66442 of the Government Code, obtain clearances from all affected Departments and Divisions, including a clearance from the Subdivision Mapping Section of the Land Development Division of Public Works for the following mapping items; mathematical accuracy; survey analysis; and correctness of certificates, signatures, etc.
15. A final guarantee will be required at the time of filing of the final map with the Registrar-Recorder/County Clerk's Office.

16. Within 30 days of the approval date of this land use entitlement or at the time of first plan check submittal, the applicant shall deposit the sum of \$2,000 (Minor Land Divisions) or \$5,000 (Major Land Divisions) with Public Works to defray the cost of verifying conditions of approval for the purpose of issuing final map clearances. This deposit will cover the actual cost of reviewing conditions of approval for Conditional Use Permits, Tentative Tract and Parcel Maps, Vesting Tentative Tract and Parcel Maps, Oak Tree Permits, Specific Plans, General Plan Amendments, Zone Changes, CEQA Mitigation Monitoring Programs and Regulatory Permits from State and Federal Agencies (Fish and Game, USF&W, Army Corps, RWQCB, etc.) as they relate to the various plan check activities and improvement plan designs. In addition, this deposit will be used to conduct site field reviews and attend meetings requested by the applicant and/or his agents for the purpose of resolving technical issues on condition compliance as they relate to improvement plan design, engineering studies, highway alignment studies and tract/parcel map boundary, title and easement issues. When 80% of the deposit is expended, the applicant will be required to provide additional funds to restore the initial deposit. Remaining balances in the deposit account will be refunded upon final map recordation.

HW



Prepared by John Chin

tr70647L-rev2.doc

http://planning.lacounty.gov/case/view/tr_070647/

Phone (626) 458-4918

Date 02-13-2014

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

REQUIREMENTS PRIOR TO GRADING PLAN APPROVAL:

1. Provide approval of:
 - a. The latest hydrology report/Water Quality Plan/Low Impact Development (LID) plan (if applicable) by the Storm Drain and Hydrology Section of Land Development Division.
 - b. The grading plan by the Geotechnical & Materials Engineering Division (GMED).
 - c. Permits and/or letters of non-jurisdiction from all State and Federal Agencies, as applicable. These agencies may include, but may not be limited to the State of California Regional Water Quality Control Board, State of California Department of Fish and Game, State of California Department of Conservation, Division of Oil, Gas, and Geothermal Resources (DOGGR), and the Army Corps of Engineers.

REQUIREMENTS PRIOR TO FINAL MAP RECORDATION:

2. Submit a grading plan for approval. The grading plan must show and call out the following items, including but not limited to: construction of all drainage devices and details, paved driveways, elevation and drainage of all pads, and LID devices (if applicable), and any required landscaping and irrigation not within a common area or maintenance easement. Acknowledgement and/or approval from all easement holders may be required.
3. A maintenance agreement or CC&Rs may be required for all privately maintained drainage devices, slopes, and other facilities.



Name Tony Hui Date 02/12/2014 Phone (626) 458-4921

P:\ldpub\SUBPCHECK\Grading\Tentative Map Reviews\70647 Rev2.doc

County of Los Angeles Department of Public Works
GEOTECHNICAL AND MATERIALS ENGINEERING DIVISION
GEOLOGIC REVIEW SHEET
900 So. Fremont Ave., Alhambra, CA 91803
TEL. (626) 458-4925

DISTRIBUTION
___ Geologist
___ Soils Engineer
1 GMED File
1 Subdivision


TENTATIVE TRACT MAP 70647
SUBDIVIDER Bonita Real Estate Investments, LLC
ENGINEER Techna Land Co. Inc.
GEOLOGIST ---
SOILS ENGINEER ---

TENTATIVE MAP DATED 22 Jan 2014 (revision) & exhibit
LOCATION La Crescenta/Montrose
GRADING BY SUBDIVIDER [Y] (Y or N) [1265 c.y.]
REPORT DATE ---
REPORT DATE ---

TENTATIVE MAP FEASIBILITY IS RECOMMENDED FOR APPROVAL FROM A GEOLOGIC STANDPOINT

THE FOLLOWING INFORMATION IS APPLICABLE TO THIS DIVISION OF LAND:

- The Final Map does *not* need to be reviewed by GMED.
- Soils engineering reports may be required prior to approval of building or grading plans.
- The Soils Engineering review dated 2/3/14 is attached.



Reviewed by Karin Burger Date February 3, 2014

Please complete a Customer Service Survey at <http://dpw.lacounty.gov/go/gmedsurvey>

COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
GEOTECHNICAL AND MATERIALS ENGINEERING DIVISION

SOILS ENGINEERING REVIEW SHEET

Address: 900 S. Fremont Ave., Alhambra, CA 91803
Telephone: (626) 458-4925
Fax: (626) 458-4913

District Office ---
PCA LX001129 / A867
Sheet 1 of 1

Tentative Tract Map 70647
Location Montrose/La Crescenta
Developer/Owner Montrose 5 View, LLC
Engineer/Architect Matirosian
Soils Engineer ---
Geologist ---

DISTRIBUTION:
 Drainage
 Grading
 Geo/Soils Central File
 District Engineer
 Geologist
 Soils Engineer
 Engineer/Architect

Review of:

Tentative Tract Map and Exhibit Dated by Regional Planning 1/22/14 (rev.)
Previous Review Sheet Dated 4/15/13

ACTION:

Tentative Map feasibility is recommended for approval, subject to conditions below:

REMARKS:

1. At the grading plan stage, submit two sets of grading plans to the Soils Section for verification of compliance with County codes and policies.
2. A soils report may be required for review of a grading or building plan. The report must comply with the provisions of "**Manual for Preparation of Geotechnical Reports**" prepared by County of Los Angeles, Department of Public Works. The Manual is available on the Internet at the following address: <http://ladpw.org/qmed/manual.pdf>

Prepared by _____



Date 2/3/14

Please complete a Customer Service Survey at <http://dpw.lacounty.gov/customer-service>.

NOTICE: Public safety, relative to geotechnical subsurface exploration, shall be provided in accordance with current codes for excavations, inclusive of the Los Angeles County Code, Chapter 11.48, and the State of California, Title 8, Construction Safety Orders.

P:\homepub\Development Review\Soils Review\Jeremy\TR 70647, Montrose, TTM-A, 3.doc

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. Dedicate the right to restrict vehicular access on Montrose Avenue.
2. Provide adequate landing area with three percent grade on the subterranean driveway exit and provide adequate sight distance from the subterranean driveway exit to the sidewalk (both directions) to the satisfaction of Public Works. Line of sight shall not be impaired by any proposed wall and/or landscaping adjacent to the driveway exit and line of sight easement dedication may be required.
3. Close any unused driveways with standard curb, gutter, and sidewalk along the property frontage on Montrose Avenue to the satisfaction of Public Works.
4. Construct new driveways to meet current Americans with Disabilities Act (ADA) requirements to the satisfaction of Public Works.
5. Repair or replace any street or parkway improvements damaged during construction along the property frontage on Montrose Avenue.
6. Plant street trees along the property frontage to the satisfaction of Public Works. Existing trees in dedicated or to be dedicated right of way shall be removed and replaced if not acceptable as street trees.
7. Execute a covenant for private maintenance of curb/parkway drains and parkway landscaping; if any to the satisfaction of Public Works.
8. Enter into an agreement with the County franchised cable TV operator (if an area is served) to permit the installation of cable in a common utility trench to the satisfaction of Public Works, or provide documentation that steps to provide cable TV to the proposed subdivision have been initiated to the satisfaction of Public Works.
9. Comply with the following street lighting requirements:
 - a. Provide street lights on concrete poles with underground wiring along the property frontage on Montrose Avenue to the satisfaction of the Department of Public Works. Submit street lighting plans showing all existing lights along with existing and/or proposed undergrounding utilities plan as soon as possible to the Street Lighting Section of the Traffic and Lighting Division to allow the maximum time for processing and approval. For additional

information, please contact the Street Lighting Section at (626) 300-4726.

- b. The proposed development is within an existing Lighting District. For acceptance of street light transfer of billing, all street lights in the development, or the current phase of the development, must be constructed according to Public Works approved plans. The contractor shall submit one complete set of “as-built” plans. Provided the above conditions are met, all street lights in the development, or the current phase of the development, have been energized, and the developer has requested a transfer of billing at least by January 1 of the previous year, the Lighting District can assume responsibility for the operation and maintenance of the street lights by July 1 of any given year. The transfer of billing could be delayed one or more years if the above conditions are not met.



Prepared by Patricia Constanza
Tr70647r-rev2.doc

Phone (626) 458-4921

Date 02-10-2014

COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
LAND DEVELOPMENT DIVISION - SEWER
TRACT NO. 70647(Rev.)

Page 1/1

TENTATIVE MAP DATED 01-22-2014
EXHIBIT MAP DATED 01-22-2014

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

- The subdivider shall install separate house laterals to serve each building in the land division.



Prepared by Tony Khalkhali
tr70647s-rev2.doc

Phone (626) 458-4921

Date 02-13-2014

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. A water system maintained by Crescenta Valley County Water District, with appurtenant facilities to serve all buildings in the subdivision. The system shall include fire hydrants of the type and location as determined by the Los Angeles County Fire Department. The water mains shall be sized to accommodate the total domestic and fire flows.
2. There shall be filed with Public Works a statement from Crescenta Valley County Water District indicating that there is adequate water capacity in the existing water system, that financial arrangements have been made, and that the water system will be operated by Crescenta Valley County Water District, and that under normal conditions, the system will meet the requirements for the subdivision.
3. If needed, easements shall be granted to the County, appropriate agency or entity for the purpose of ingress, egress, construction, and maintenance of all infrastructures constructed for this land division to the satisfaction of Public Works.
4. Submit landscape and irrigation plans for the common area in the land division, with landscape area greater than 2,500 square feet, in accordance with the Water Efficient Landscape Ordinance.



Prepared by Tony Khalkhali
tr70647w-rev2.doc

Phone (626) 458-4921

Date 02-13-2014