



COUNTY OF LOS ANGELES

DEPARTMENT OF PARKS AND RECREATION

"Creating Community Through People, Parks and Programs"

Russ Guiney, Director



June 21, 2012

TO: Jodie Sackett, Planner  
Land Divisions Section  
Regional Planning

FROM: Olga Ruano *OR*  
Trails Section  
Parks and Recreation

SUBJECT: **VESTING TENTATIVE TRACT MAP NO. 71892**  
**(MAP STAMPED BY REGIONAL PLANNING ON MAY 17, 2012)**

The Department of Parks and Recreation (Department) has completed the review of VTTM No. 71892. The Department requires a sixteen foot (16') wide trail easement.

Because of the necessity to show the trail alignment as it pertains to topographical lines, all information pertaining to trail requirements, must be shown on the tentative map, prior to final map recordation.

X      **The map is on HOLD.**

1. A proposed trail is located on or adjacent to the project site (APN 3217-020-002). Show on map a sixteen foot wide easement for use as non-motorized multi-use trail and denote as "Vasquez Loop Trail". Contact Park Planner to discuss preferred location of trail alignment.
2. Cross-slope (Out-slope towards Crown Valley Road) of cement driveway not to exceed 3% for full sixteen (16) foot width of required trail easement.
3. Bush-hammer finish required on cement driveways ("A" Street) at full width of trail easement (sixteen feet) to accommodate for safe trail user crossing.

For any questions concerning trail alignment or other trail requirements, please contact me at (213) 738-2014.

G:\1-PND4-Trails\TRAIL REPORTS\SCMs\71892\Initial Trail Report VTTM No 71892 Revised June 18 2012.doc