



COUNTY OF LOS ANGELES
FIRE DEPARTMENT

5823 Rickenbacker Road
Commerce, California 90040

CONDITIONS OF APPROVAL FOR SUBDIVISION - UNINCORPORATED

Subdivision No: TR 71925 Map Date: April 19, 2012 - Ex A

C.U.P. _____ Vicinity _____

- FIRE DEPARTMENT HOLD** on the tentative map shall remain until verification from the Los Angeles County Fire Dept. Planning Section is received, stating adequacy of service. Contact (323) 881-2404.
- Access shall comply with Title 21 (County of Los Angeles Subdivision Code) and Section 503 of the Fire Code, which requires all weather access. All weather access may require paving.
- Fire Department access shall be extended to within 150 feet distance of any exterior portion of all structures.
- Where driveways extend further than 150 feet and are of single access design, turnarounds suitable for fire protection equipment use shall be provided and shown on the final map. Turnarounds shall be designed, constructed and maintained to insure their integrity for Fire Department use. Where topography dictates, turnarounds shall be provided for driveways that extend over 150 feet in length.
- The private driveways shall be indicated on the final map as "Private Driveway and Firelane" with the widths clearly depicted. Driveways shall be maintained in accordance with the Fire Code.
- Vehicular access must be provided and maintained serviceable throughout construction to all required fire hydrants. All required fire hydrants shall be installed, tested and accepted prior to construction.
- This property is located within the area described by the Fire Department as "Very High Fire Hazard Severity Zone" (formerly Fire Zone 4). A "Fuel Modification Plan" shall be submitted and approved prior to Tentative Map clearance. (Contact: Fuel Modification Unit, Fire Station #32, 605 North Angeleno Avenue, Azusa, CA 91702-2904, Phone (626) 969-5205 for details).
- Provide Fire Department or City approved street signs and building access numbers prior to occupancy.
- Additional fire protection systems shall be installed in lieu of suitable access and/or fire protection water.
- The final concept map, which has been submitted to this department for review, has fulfilled the conditions of approval recommended by this department for access only.
- These conditions must be secured by a C.U.P. and/or Covenant and Agreement approved by the County of Los Angeles Fire Department prior to final map clearance.
- The Fire Department has no additional requirements for this division of land.

Comments: **The Fire Department does NOT recommend approval of this subdivision as presently submitted. See additional sheet for details and corrections required.**

By Inspector: Juan C. Padilla Date May 16, 2012

Land Development Unit – Fire Prevention Division – (323) 890-4243, Fax (323) 890-9783



COUNTY OF LOS ANGELES
FIRE DEPARTMENT

5823 Rickenbacker Road
Commerce, California 90040

WATER SYSTEM REQUIREMENTS - UNICORPORATED

Subdivision No: TR 71925 Map Date: April 19, 2012 - Ex A

Revised Report _____

- The County Forester and Fire Warden is prohibited from setting requirements for water mains, fire hydrants and fire flows as a condition of approval for this division of land as presently zoned and/or submitted. However, water requirements may be necessary at the time of building permit issuance.
- The required fire flow for public fire hydrants at this location is **1250** gallons per minute at 20 psi for a duration of **2** hours, over and above maximum daily domestic demand. **1** Hydrant(s) flowing simultaneously may be used to achieve the required fire flow.
- The required fire flow for private on-site hydrants is _____ gallons per minute at 20 psi. Each private on-site hydrant must be capable of flowing _____ gallons per minute at 20 psi with two hydrants flowing simultaneously, one of which must be the furthest from the public water source.
- Fire hydrant requirements are as follows:
Install _____ public fire hydrant(s). Upgrade / Verify existing **2** public fire hydrant(s).
Install _____ private on-site fire hydrant(s).
- All hydrants shall measure 6" x 4" x 2-1/2" brass or bronze, conforming to current AWWA standard C503 or approved equal. All on-site hydrants shall be installed a minimum of 25' feet from a structure or protected by a two (2) hour rated firewall.
 Location: As per map on file with the office.
 Other location: _____
- All required fire hydrants shall be installed, tested and accepted or bonded for prior to Final Map approval. Vehicular access shall be provided and maintained serviceable throughout construction.
- The County of Los Angeles Fire Department is not setting requirements for water mains, fire hydrants and fire flows as a condition of approval for this division of land as presently zoned and/or submitted.
- Additional water system requirements will be required when this land is further subdivided and/or during the building permit process.
- Hydrants and fire flows are adequate to meet current Fire Department requirements.
- Fire hydrant upgrade is not necessary, if existing hydrant(s) meet(s) fire flow requirements. Submit original water availability form to our office.

Comments: **Submit 2 original fire flow availability form, FORM 195, for the existing public fire hydrants closest to the property lot frontages on 3rd Street and Aracadia Drive.**

All hydrants shall be installed in conformance with Title 20, County of Los Angeles Government Code and County of Los Angeles Fire Code, or appropriate city regulations. This shall include minimum six-inch diameter mains. Arrangements to meet these requirements must be made with the water purveyor serving the area.

By Inspector Juan C. Padilla Date May 16, 2012

Land Development Unit – Fire Prevention Division – (323) 890-4243, Fax (323) 890-9783



COUNTY OF LOS ANGELES
FIRE DEPARTMENT

5823 Rickenbacker Road
Commerce, California 90040

LAND DEVELOPMENT UNIT REQUIREMENTS
ADDITIONAL PAGE

Subdivision No: TR 71925 **Map Date:** April 19, 2012 - Ex A

EXHIBIT MAP – HOLDS

- 1 The driveway used for fire department apparatus access for this project shall provide a minimum pavement width of 26 feet, clear to the sky. Remove the "Fire Dept. Access" note. Indicate compliance on the Exhibit Map.
- 2 The driveway used for fire department apparatus access shall be labeled as "Private Driveway and Fire Lane". Indicate compliance on the Exhibit Map.
- 3 The proposed gate shall provide a minimum setback of 20 feet from the future public right of way line. Indicate compliance on the Exhibit Map.
- 4 Provide a gate detail indicating the setback from the right of way, width when fully open, location of fire department key pad/knox box, and a note indicating compliance with section 503.5 of the County of Los Angeles Fire Code. The gate detail maybe submitted directly to the Fire Department on a separate exhibit.

EXHIBIT MAP – CONDITIONS OF APPROVAL

- 5 A reciprocal access agreement for the proposed private driveway and fire lane is required. Compliance is required prior to Final Map to the satisfaction of Regional Planning.

By Inspector: Juan C. Padilla

Date: May 16, 2012

Land Development Unit – Fire Prevention Division – (323) 890-4243, Fax (323) 890-9783