

It is recommended that this tentative map not be approved at this time. This recommendation is based upon information or lack of information that is available concerning the subject property. The removal of this recommendation is contingent upon the submission and satisfactory review of the following:

- 1) As previously requested, an approved hydrology report. Please see attached Storm Drain and Hydrology review sheet (Comments 1 and 3) for comments and requirements. The hydrology report shall be submitted directly to Public Works.
- 2) A revised tentative map and a revised exhibit map are required to show the following additional items:
 - a. As previously requested, on the exhibit map, label all easements as "to remain", "to be relocated", or "to be abandoned". If easement is to be abandoned, indicate the proposed timing of the abandonment. Label the status of Easement Note No. 3 on the tentative map.
 - b. As previously requested, please see attached Storm Drain and Hydrology review sheet (Comment 2).
 - c. Please see attached Sewer review sheet for comments and requirements.

HCW
Prepared by John Chin
tr72684L-rev2.doc
<http://planning.lacounty.gov/case/view/tr072684/>

Phone (626) 458-4918

Date 09-29-2014



COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS
LAND DEVELOPMENT DIVISION
HYDROLOGY UNIT

TRACT MAP NO. 072684

TENTATIVE MAP DATED 09/04/2014
EXHIBIT MAP 09/04/2014

Approval and clearance of the tentative map is subjected to compliance with the following **drainage** comments:

1. Prior to tentative map approval for drainage, submit a hydrology report showing the extent of drainage impacts and provide mitigation acceptable to the County. The analysis should address increases in runoff, any change in drainage patterns, debris producing areas, and the capacity of existing storm drain facilities. Provide line identification of all proposed drainage facilities. Preliminary soils and geology reports related to debris, retention, and detention basins may be required based on geographic and adverse geotechnical conditions. Provide engineering calculations to support sizing of debris, retention, and detention basins. Provide approximate flood hazard and bank erosion setbacks and lot identifications (as needed). Show slopes for existing and proposed streets. Provide a drainage/grading covenant for any offsite work.
2. Add a note to the tentative map stating, "The Developer/Engineer acknowledge that the size of the water quality and/or flood control basin will be reviewed at the improvement plan stage. Significant change of the size of the basin from what is shown on the tentative map may result in revising planning documents by the Department of Regional Planning."
3. A water quality section of the Hydrology Report is required to comply with the LID requirements of Los Angeles County Code Section 12.84 (<http://library.municode.com/index.aspx?clientId=16274>).

Reviewed by  Date 09/25/2014 Phone (626) 458-4921
Andrew Ross

TENTATIVE MAP DATED 09-04-2014
EXHIBIT MAP DATED 09-04-2014

It is recommended that this tentative map and/or exhibit map not be approved at this time. This recommendation is based upon information or lack of information that is available concerning the subject property. The removal of this recommendation is contingent upon the submission and satisfactory review of the following:

A revised tentative and/or exhibit map is required to show the following items:

- Telegraph Road is an existing major highway. Construct manhole 6 feet from curb (on pavement side) and provide right angle connection from proposed sewer to existing sewer system with proposed manhole on Telegraph Road.



Prepared by Imelda Ng
tr72684s-rev2.doc

Phone (626) 458-4921


Date 09-25-2014

COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
LAND DEVELOPMENT DIVISION – SUBDIVISION
TRACT NO. 072684 (Rev.)

Page 1/1

TENTATIVE MAP DATED 09-04-2014
EXHIBIT "A" MAP DATED 09-04-2014

- If this recommendation of disapproval is changed to a recommendation of approval based on additional information, the following reports would be recommended for inclusion in the conditions of tentative approval:

Prepared by  John Chin

Phone (626) 458-4918

Date 09-29-2014

tr72684L-rev2.doc

<http://planning.lacounty.gov/case/view/tr072684/>

The following reports consisting of ___ pages are the recommendations of Public Works.

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. Details and notes shown on the tentative map are not necessarily approved. Any details or notes which may be inconsistent with requirements of ordinances, general conditions of approval, or Department policies must be specifically approved in other conditions, or ordinance requirements are modified to those shown on the tentative map upon approval by the Advisory agency.
2. Easements are tentatively required, subject to review by the Director of Public Works to determine the final locations and requirements.
3. Easements shall not be granted or recorded within areas proposed to be granted, dedicated, or offered for dedication for public streets, highways, access rights, building restriction rights, or other easements until after the final map is filed with the Registrar-Recorder/County Clerk's Office. If easements are granted after the date of tentative approval, a subordination must be executed by the easement holder prior to the filing of the final map.
4. In lieu of establishing the final specific locations of structures on each lot at this time, the owner, at the time of issuance of a grading or building permit, agrees to develop the property in conformance with the County Code and other appropriate ordinances such as the Building Code, Plumbing Code, Grading Ordinance, Highway Permit Ordinance, Mechanical Code, Zoning Ordinance, Undergrounding of Utilities Ordinance, Water Ordinance, Sanitary Sewer and Industrial Waste Ordinance, Electrical Code, and Fire Code. Improvements and other requirements may be imposed pursuant to such codes and ordinances.
5. All easements existing at the time of final map approval must be accounted for on the approved tentative map. This includes the location, owner, purpose, and recording reference for all existing easements. If an easement is blanket or indeterminate in nature, a statement to that effect must be shown on the tentative map in lieu of its location. If all easements have not been accounted for, submit a corrected tentative map to the Department of Regional Planning for approval.

6. Adjust, relocate, and/or eliminate lot lines, lots, streets, easements, grading, geotechnical protective devices, and/or physical improvements to comply with ordinances, policies, and standards in effect at the date the County determined the application to be complete all to the satisfaction of Public Works.
7. If applicable, quitclaim or relocate easements running through proposed structures.
8. Show the remainder of the last legally created parcel as "Not a Part" on any final map to the satisfaction of the Director of Public Works.
9. Place standard condominium notes on the final map to the satisfaction of Public Works.
10. Prior to final approval of the tract map submit a notarized affidavit to the Director of Public Works, signed by all owners of record at the time of filing of the map with the Registrar-Recorder/County Clerk's Office, stating that any proposed condominium building has not been constructed or that all buildings have not been occupied or rented and that said building will not be occupied or rented until after the filing of the map with the Registrar-Recorder/County Clerk's Office.
11. Label driveways and multiple access strips as "Private Driveway and Fire Lane" and delineate on the final map to the satisfaction of Public Works.
12. Remove existing buildings prior to final map approval. Demolition permits are required from the Building and Safety office.
13. A Mapping & Property Management Division house numbering clearance is required prior to approval of the final map.
14. A final tract map must be processed through the Director of Public Works prior to being filed with the Registrar-Recorder/County Clerk's Office.
15. Prior to submitting the tract map to the Director of Public Works for examination pursuant to Section 66442 of the Government Code, obtain clearances from all affected Departments and Divisions, including a clearance from the Subdivision Mapping Section of the Land Development Division of Public Works for the following mapping items; mathematical accuracy; survey analysis; and correctness of certificates, signatures, etc.
16. A final guarantee will be required at the time of filing of the final map with the Registrar-Recorder/County Clerk's Office.

17. Within 30 days of the approval date of this land use entitlement or at the time of first plan check submittal, the applicant shall deposit the sum of \$2,000 (Minor Land Divisions) or \$5,000 (Major Land Divisions) with Public Works to defray the cost of verifying conditions of approval for the purpose of issuing final map clearances. This deposit will cover the actual cost of reviewing conditions of approval for Conditional Use Permits, Tentative Tract and Parcel Maps, Vesting Tentative Tract and Parcel Maps, Oak Tree Permits, Specific Plans, General Plan Amendments, Zone Changes, CEQA Mitigation Monitoring Programs and Regulatory Permits from State and Federal Agencies (Fish and Game, USF&W, Army Corps, RWQCB, etc.) as they relate to the various plan check activities and improvement plan designs. In addition, this deposit will be used to conduct site field reviews and attend meetings requested by the applicant and/or his agents for the purpose of resolving technical issues on condition compliance as they relate to improvement plan design, engineering studies, highway alignment studies and tract/parcel map boundary, title and easement issues. When 80% of the deposit is expended, the applicant will be required to provide additional funds to restore the initial deposit. Remaining balances in the deposit account will be refunded upon final map recordation.

HW
Prepared by John Chin
tr72684L-rev2.doc
<http://planning.lacounty.gov/case/view/tr072684/>

Phone (626) 458-4918

Date 09-29-2014

County of Los Angeles Department of Public Works
Geotechnical and Materials Engineering Division
GEOLOGIC AND SOILS ENGINEERING REVIEW SHEET
900 S. Fremont Avenue, Alhambra, CA 91803

Tentative Tract / Parcel Map	72684	Tentative Map Dated	9/4/14 (Exhibit)	Parent Tract	
Grading By Subdivider? [Y] (Y or N)	_____ yd ³	Location	Whittier	APN	
Geologist	---	Subdivider	Brandywine Homes		
Soils Engineer	---	Engineer/Arch.	DMS Consultants, Inc.		

Review of:


Geologic Report(s) Dated: _____
 Soils Engineering Report(s) Dated: _____
 Geotechnical Report(s) Dated: _____
 References: _____

TENTATIVE MAP FEASIBILITY IS RECOMMENDED FOR APPROVAL FROM A GEOTECHNICAL STANDPOINT

THE FOLLOWING CONDITIONS MUST BE FULFILLED:

1. At the grading plan stage, submit grading plans to the GMED for verification of compliance with County Codes and policies.
2. A grading plan must be geotechnically approved by the GMED prior to Final Map approval. The grading depicted on the plan must agree with the grading depicted on the tentative tract or parcel map and the conditions approved by the Planning Commission. If the subdivision is to be recorded prior to the completion and acceptance of grading, corrective geologic bonds may be required.
3. Geotechnical report(s) may be required prior to approval of grading or building plans. Report(s) must comply with the provisions of the County of Los Angeles Department of Public Works Manual for Preparation of Geotechnical Reports. The Manual is available at: <http://dpw.lacounty.gov/gmed/permits/docs/manual.pdf>.
4. The Final Map does **not** need to be reviewed by the Geotechnical and Materials Engineering Division.

Prepared by



Geir R. Matheson
 Ricardo Lopez Maldonado
 Geology Section

Date 9/25/14

1. Approval of this map pertaining to grading is recommended.

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

REQUIREMENTS PRIOR TO GRADING PLAN APPROVAL:

2. Provide approval of:
 - a. The latest drainage concept/hydrology/Standard Urban Stormwater Mitigation Plan (SUSMP), if applicable/Low Impact Development (LID) plan by the Storm Drain and Hydrology Section of Land Development Division.
 - b. Per County Code Section 12.84.430 (C), follow USEPA guidance regarding "Managing Wet Weather with Green Infrastructure: Green Streets 26" (December 2008 EPA-833-F-009) to the maximum extent practicable.
 - c. The grading plan by the Geotechnical & Materials Engineering Division (GMED).
 - d. Permits and/or letters of non-jurisdiction from all State and Federal Agencies, as applicable. These agencies may include, but may not be limited to the State of California Regional Water Quality Control Board, State of California Department of Fish and Wildlife, State of California Department of Conservation, Division of Oil, Gas, and Geothermal Resources (DOGGR), and the Army Corps of Engineers.
3. Prior to rough grade certification ("approval", J105.7), submit landscape and irrigation plans for each commercial/multi-family/open space lot with slope planting in the land division with landscape area greater than or equal to 2,500 square feet, in accordance with the Water Efficient Landscape Ordinance.

Name N. Said



Date 09-15-2014

Phone (626) 458-4921

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. Provide standard property line return radii of 27 feet at the intersection of Telegraph Road and Bramblebush Avenue plus additional right of way for corner cut off to meet current guidelines of the Americans with Disabilities Act (ADA) to the satisfaction of Public Works.
2. Dedicate additional right of way at the knuckle intersection of Bramblebush Avenue and Honeysuckle Lane along the property frontage to the satisfaction of Public Works.
3. Close any unused driveway with standard curb, gutter, and sidewalk along the property frontage on streets within this subdivision.
4. Construct new driveway entrance to meet ADA requirements on Bramblebush Avenue to the satisfaction of Public Works. Additional right of way dedication is required to accommodate ADA requirements along the driveway entrance to the satisfaction of Public Works.
5. Construct 5' wide sidewalk (adjacent to the right of way) along the property frontage on Bramblebush Avenue and Honeysuckle Lane to the satisfaction of Public Works.
6. Repair any damaged improvements during construction to the satisfaction of Public Works.
7. Reconstruct the curb ramp at the intersection of Telegraph Road and Bramblebush Avenue to meet current ADA requirements to the satisfaction of Public Works. Remove the block wall from the proposed corner-cutoff to the satisfaction of Public Works.
8. Construct full-width sidewalk and curb ramps at all returns.
9. Plant street trees along the property frontage on Telegraph Road, Bramblebush Avenue and Honeysuckle Lane to the satisfaction of Public Works. Existing trees in dedicated or to be dedicated right of way shall be removed and replaced if not acceptable as street trees.
10. Construct drainage improvements (and parkway drains, if needed) for street drainage to the satisfaction of Public Works.
11. Execute a covenant for private maintenance of curb/parkway drains; if any and

landscaped median/parkway along the property frontages to the satisfaction of Public Works.

12. Prior to final map approval, enter into an agreement with the County franchised cable TV operator (if an area is served) to permit the installation of cable in a common utility trench to the satisfaction of Public Works or provide documentation that steps to provide cable TV to the proposed subdivision have been initiated to the satisfaction of Public Works.
13. If a median opening along Bramblebush Avenue is required to meet Fire Department's access requirements, provide a minimum pavement width of 22 feet to accommodate our minimum requirements for left turn pockets on both southerly and northerly directions. The striping and median detail as shown on the Exhibit "A" plan view and typical section are not necessarily approved and are subject to design modifications to the satisfaction of Public Works. A detailed 1" = 40' scaled striping plan may be required to the satisfaction of Public Works.
14. An assessment district shall be formed to finance the future ongoing maintenance and capital replacement of all green street infrastructure identified by the Department of Public Works. The Subdivider shall deposit the first year's total assessment based on the Public Works engineering report. This will fund the first year's maintenance after the facilities are accepted. The second and subsequent year's assessment will be collected through the property tax bill. This is required to the satisfaction of the Department of Public Works.
15. Comply with the following street lighting requirements or as otherwise modified by Public Works:
 - a. Provide street lights on concrete poles with underground wiring along the property frontage on Telegraph Road to the satisfaction of Public Works. Submit street lighting plans along with existing and/or proposed underground utilities plans as soon as possible for review and approval to the Street Lighting Section of the Traffic and Lighting Division. For additional information, please contact the Street Lighting Section at (626) 300-4726.
 - b. The proposed development or portions thereof, are not within an existing Lighting District. Annexation and assessment balloting are required. Street lighting plans cannot be approved prior to completion of annexation process. Upon submittal of the street lighting plans, the applicant shall comply with conditions listed below in order for the Lighting District to pay for the future operation and maintenance of the street lights. The Board of Supervisors must approve the annexation and levy of assessment (should assessment

balloting favor levy of assessment) prior to Public Works approving street lighting plans. It is the sole responsibility of the owner/developer of the project to have all street lighting plans approved prior to the issuance of building permits. The required street lighting improvements shall be the sole responsibility of the owner/developer of the project and the installation must be accepted per approved plans prior to the issuance of a certificate of occupancy.

- 1) Provide business/property owner's name(s), mailing address(es), site address, Assessor Parcel Number(s), and Parcel Boundaries in either Microstation or Auto CADD format of territory to be developed to the Street Lighting Section.
 - 2) Submit a map of the proposed development including any roadways conditioned for street lights to Street Lighting Section. Contact the Street Lighting Section for map requirements and with any questions at (626) 300-4726.
- c. The annexation and assessment balloting process takes approximately twelve months or more to complete once the above information is received and approved. Therefore, untimely compliance with the above will result in a delay in receiving approval of the street lighting plans or in filing the final subdivision map for recordation. Information on the annexation and the assessment balloting process can be obtained by contacting Street Lighting Section at (626) 300-4726.
- d. For acceptance of street light transfer of billing, the area must be annexed into the Lighting District and all street lights in the development, or the approved phase of the development, must be constructed according to Public Works approved plans. The contractor shall submit one complete set of "as-built" plans. The Lighting District can assume responsibility for the operation and maintenance of the street lights by July 1 of any given year, provided the above conditions are met, all street lights in the development, or approved project phase, have been constructed per Public Works approved plans and energized, and the developer has requested a transfer of billing at least by January 1 of the previous year. The transfer of billing could be delayed one or more years if the above conditions are not met. The Lighting District cannot pay for the operation and maintenance of street lights on gated private and future street(s).



The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. A water system maintained by the water purveyor, with appurtenant facilities to serve all buildings/lots in the land division, must be provided. The system shall include fire hydrants of the type and location (both on-site and off-site) as determined by the Fire Department. The water mains shall be sized to accommodate the total domestic and fire flows.
1. There shall be filed with Public Works a statement from the water purveyor indicating that the water system will be operated by the purveyor, and that under normal conditions, the system will meet the requirements for the land division, and that water service will be provided to each building/lot.
5. If needed, easements shall be granted to the County, appropriate agency or entity for the purpose of ingress, egress, construction and maintenance of all infrastructures constructed for this land division to the satisfaction of Public Works.
6. Prior to obtaining the building permit from the Building and Safety Office, submit landscape and irrigation plans for each commercial/multi-family/open space lot in the land division, with landscape area greater than 2,500 square feet, in accordance with the Water Efficient Landscape Ordinance.
8. This tentative map is recommended for approval through the term of the will serve letter issued by the water purveyor which will expire on 01/23/2015. Should the tentative map not be approved prior to expiration, the approval shall be withheld until the water purveyor has re-issued its will serve letter.
10. The applicant shall comply with the requirements as indicated on the attached letter dated 07/23/2014 from the Orchard Dale Water District to the satisfaction of Public Works.
11. If needed, easements shall be granted to the County, appropriate agency or entity for the purpose of ingress, egress, construction and maintenance of all infrastructures constructed for this land division to the satisfaction of Public Works.
12. Depict all line of sight easements on the landscaping and grading plans.
13. If recycle water is available, install a separate water irrigation systems for recycled water use per landscape plans.
14. If recycle water is available, the recycled water irrigation systems shall be designed and operated in accordance with all local and State Codes as required per AB 1881.