

The following reports consisting of 8 pages are the recommendations of Public Works.

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. Details and notes shown on the tentative map are not necessarily approved. Any details or notes which may be inconsistent with requirements of ordinances, general conditions of approval, or Department policies must be specifically approved in other conditions, or ordinance requirements are modified to those shown on the tentative map upon approval by the Advisory agency.
2. Easements are tentatively required, subject to review by the Director of Public Works to determine the final locations and requirements.
3. Easements shall not be granted or recorded within areas proposed to be granted, dedicated, or offered for dedication for public streets, highways, access rights, building restriction rights, or other easements until after the final map is filed with the Registrar-Recorder/County Clerk's Office. If easements are granted after the date of tentative approval, a subordination must be executed by the easement holder prior to the filing of the final map.
4. In lieu of establishing the final specific locations of structures on each lot at this time, the owner, at the time of issuance of a grading or building permit, agrees to develop the property in conformance with the County Code and other appropriate ordinances such as the Building Code, Plumbing Code, Grading Ordinance, Highway Permit Ordinance, Mechanical Code, Zoning Ordinance, Undergrounding of Utilities Ordinance, Water Ordinance, Sanitary Sewer and Industrial Waste Ordinance, Electrical Code, and Fire Code. Improvements and other requirements may be imposed pursuant to such codes and ordinances.
5. All easements existing at the time of final map approval must be accounted for on the approved tentative map. This includes the location, owner, purpose, and recording reference for all existing easements. If an easement is blanket or indeterminate in nature, a statement to that effect must be shown on the tentative map in lieu of its location. If all easements have not been accounted for, submit a corrected tentative map to the Department of Regional Planning for approval.
6. Adjust, relocate, and/or eliminate lot lines, lots, streets, easements, grading, geotechnical protective devices, and/or physical improvements to comply with ordinances, policies, and standards in effect at the date the County determined the application to be complete all to the satisfaction of Public Works.

7. If applicable, quitclaim or relocate easements running through proposed structures.
8. Thirty days prior to requesting final approval of the tract map submit gummed mailing labels for each tenant in the structure to be converted, a notarized affidavit signed by all of the owners listing all vacant units, a minimum deposit of twenty-five (\$25) dollars for each occupied unit, and recorded copies of all covenants and agreements applicable to this conversion project to the Director of Public Works. Copies of the covenants and agreements must be mailed to all tenants by the applicant at least thirty days prior to final approval.
9. Place standard condominium conversion notes on the final map to the satisfaction of Public Works.
10. Label driveways and multiple access strips as "Private Driveway and Fire Lane" and delineate on the final map to the satisfaction of Public Works and Fire Department.
11. Reserve reciprocal easements for drainage, ingress/egress, sewer, water, utilities, right to grade, and maintenance purposes, in documents over the common private driveways to the satisfaction of Public Works.
12. A final tract map must be processed through the Director of Public Works prior to being filed with the Registrar-Recorder/County Clerk's Office.
13. Prior to submitting the tract map to the Director of Public Works for examination pursuant to Section 66442 of the Government Code, obtain clearances from all affected Departments and Divisions, including a clearance from the Subdivision Mapping Section of the Land Development Division of Public Works for the following mapping items; mathematical accuracy; survey analysis; and correctness of certificates, signatures, etc.
14. A final guarantee will be required at the time of filing of the final map with the Registrar-Recorder/County Clerk's Office.
15. Within 30 days of the approval date of this land use entitlement or at the time of first plan check submittal, the applicant shall deposit the sum of \$5,000 with Public Works to defray the cost of verifying conditions of approval for the purpose of issuing final map clearances.



**COUNTY OF LOS ANGELES**  
**DEPARTMENT OF PUBLIC WORKS**

900 SOUTH FREMONT AVENUE  
ALHAMBRA, CALIFORNIA 91803-1331  
WWW.DPW.LACOUNTY.GOV

TRACT MAP NO.: 73392

TENTATIVE MAP DATE: 09/29/2015

**STORM DRAIN AND HYDROLOGY SECTION CONDITIONS OF APPROVAL, PHONE: (626) 458-4921**

**Prior to recordation of a Final Map or Parcel map Waiver:**

1. Approval of this map pertaining to drainage is recommended. (No grading is proposed on the Application)

Note: This clearance is only for the tentative map. If a Conditional Use Permit is required by the Department of Regional Planning, a drainage concept may be required prior to clearing the Conditional Use Permit.

Name *Ernesto J Rivera* Date 10/22/2015 Phone (626) 458-4921  
Ernesto J Rivera

County of Los Angeles Department of Public Works  
Geotechnical and Materials Engineering Division  
GEOLOGIC AND SOILS ENGINEERING REVIEW SHEET  
900 S. Fremont Avenue, Alhambra, CA 91803

Tentative Tract Map	73392	Tentative Map Dated	9/25/15 (Rev.)	Parent Tract	
Grading By Subdivider? [ N ] (Y or N)	---	Location	Covina	APN	
Geologist	---	Subdivider	Alliance Property LLC		
Soils Engineer	---	Engineer/Arch.	Marshall Engineering Group		

Review of:

Geologic Report(s) Dated: \_\_\_\_\_  
 Soils Engineering Report(s) Dated: \_\_\_\_\_  
 Geotechnical Report(s) Dated: \_\_\_\_\_  
 References: \_\_\_\_\_


TENTATIVE MAP FEASIBILITY IS RECOMMENDED FOR APPROVAL FROM A GEOTECHNICAL STANDPOINT

THE FOLLOWING INFORMATION IS APPLICABLE TO THIS DIVISION OF LAND:

- The Final Map does **not** need to be reviewed by the Geotechnical and Materials Engineering Division.
- Geotechnical report(s) may be required prior to approval of building plans. Report(s) must comply with the provisions of the County of Los Angeles Department of Public Works *Manual for Preparation of Geotechnical Reports*. The Manual is available at: <http://dpw.lacounty.gov/gmed/permits/docs/manual.pdf>.

Prepared by

  
 William Man  
 Soils Section



  
 Charles Nestle  
 Geology Section

Date 10/21/15

Please complete a Customer Service Survey at <http://dpw.lacounty.gov/go/gmedsurvey>

NOTICE: Public safety, relative to geotechnical subsurface exploration, shall be provided in accordance with current codes for excavations, inclusive of the Los Angeles County Code, Chapter 11.48, and the State of California, Title 8, Construction Safety Orders.

COUNTY OF LOS ANGELES  
DEPARTMENT OF PUBLIC WORKS  
LAND DEVELOPMENT DIVISION - GRADING  
TRACT NO. 073392

Page 1/1

TENTATIVE MAP DATED 07-28-2015  
EXHIBIT MAP DATED 07-28-2015

1. Approval of this map pertaining to grading is recommended (no grading is proposed).

Name Nazem Said  Date 8/12/2015 Phone (626) 458-4921  
P:\ldpub\SUBPCHECK\Plan Checking Files\Tract Map\TR 073392\GP 073392\2015-07-29 TTR 073392 SUBMITTAL

COUNTY OF LOS ANGELES  
DEPARTMENT OF PUBLIC WORKS  
LAND DEVELOPMENT DIVISION - ROAD  
TRACT MAP NO. 073392

Page 1/1

TENTATIVE MAP DATED 09-29-2015  
EXHIBIT MAP DATED 09-29-2015

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. Prior to final map approval, enter into an agreement with the County franchised cable TV operator (if an area is served) to permit the installation of cable in a common utility trench to the satisfaction of Public Works; or provide documentation that steps to provide cable TV to the proposed subdivision have been initiated to the satisfaction of Public Works.



Prepared by Erik Rodriguez

tr073392r-rev2

Phone (626) 458-4921

Date 10-20-2015

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. A sewer area study for the proposed subdivision (PC12281AS, dated 05-09-2016) was reviewed and approved. No additional mitigation measures are required. The sewer area study shall be invalidated should there be an increase in the total number of dwelling units, an increase in the density, dwelling units occur on previously identified building restricted lots, a change in the proposed sewer alignment, an increase in the tributary sewershed, a change in the sewer connection points, or the adoption of a land use plan or a revision to the current plan. A revision to the approved sewer area study may be allowed at the discretion of the Director of Public Works. The approved sewer area study shall remain valid for two years from the date of sewer area study approval. After this period of time, an update of the area study shall be submitted by the applicant if determined to be warranted by Public Works.

  
Prepared by Imelda Ng  
tr73392s-rev2(rev'd 05-10-16)

Phone (626) 458-4921

Date 05-10-2016

The subdivision shall conform to the design standards and policies of Public Works, in particular, but not limited to the following items:

1. A water system maintained by the water purveyor, with appurtenant facilities to serve all lots in the land division, must be provided. The system shall include fire hydrants of the type and location (both on-site and off-site) as determined by the Fire Department. The water mains shall be sized to accommodate the total domestic and fire flows.
2. The applicant shall comply with the requirements as stipulated by the attached Will Serve letter dated 05/26/2015 from the Golden State Water Company to the satisfaction of Public Works. The Will Serve letter will expire on 05/26/2016 it shall be sole responsibility of the applicant to renew the aforementioned Will Serve letter upon expiration and abide by all requirements of the water purveyor.
3. Submit landscape and irrigation plans for each multi-family lot in the land division, with landscape area greater than 500 square feet, in accordance with the Water Efficient Landscape Ordinance. Landscaping must have a separate meter.



Prepared by Tony Khalkhali  
tr073392w-rev2.doc

Phone (626) 458-4921

Date 10-22-2015